



**James Island Charter High School  
Facilities/Maintenance Department**

Marty Monette, Facilities Director  
Maintenance Office 843-762-3788  
Main Office 843-762-2754  
Fax 843-762-8392

Dec. 14th, 2020

1. The gym floor was re-finished over the Thanksgiving break.
2. The sidewalk that was torn up to repair the water main leak at the softball press box in Nov. has been re-poured.
3. Annual fire testing of the kitchen exhaust hood and the exhaust hood in room 114 is complete, both passed without issue.
4. The "slow - school zone" flashing lights at either end of the school on Fort Johnson Rd. is no longer manually turned on daily. It has been upgraded to a scheduled timer, maintained and operated by the Charleston Co. Signal Division.
5. JICHHS Facilities Maint. Dept. has received and processed 81 work orders from Nov 16th, to the present.

Marty Monette  
Facilities Director, JICHHS

