



**James Island Charter High School
Facilities/Maintenance Department**

Marty Monette, Facilities Director
Maintenance Office 843-762-3788
Main Office 843-762-2754
Fax 843-762-8392

March 15th, 2021

1. The annexair - fresh air unit serving the fieldhouse had 2 hot gas bypass valves replaced, and is operational again.
2. The natural gas valve in the hot water heater serving the PAC has been replaced, it is operational again.
3. The bad compressor in WHP#2 in trailer #7 has been replaced.
4. The construction team received authorization this week to have power restored back to the track shed.
5. The JICHS Facilities Maintenance Dept. has received and processed 59 work orders from Feb. 22 the present.

Marty Monette
Facilities Director, JICHS

