



**James Island Charter High School
Facilities/Maintenance Department**

Marty Monette, Facilities Director
Maintenance Office 843-762-3788
Main Office 843-762-2754
Fax 843-762-8392

February 24th, 2020

1. The pressure reducing backflow preventer that serves the water supply associated with the east side of the campus was replaced due to mechanical failure.
2. The HVAC unit serving room 203 had the refrigerant accumulator replaced due to a hole corroding through it.
3. The Annex air, fresh air make up units serving the PAC and the field house had their annual operational testing, both units passed operating at 100%.
4. JICHHS Facilities Maint. Dept. has received and processed 88 work orders from January 27th to the present.

Marty Monette
Facilities Director, JICHHS

